

# Measurement of Cavity BPM Performance

1. Goal
2. Measurement with Network Analyzer
3. Measurement with Beam
4. Summary and Outlook

D. Lipka, J. Lund-Nielsen, D. Nölle, M. Siemens, S. Vilcins, Th. Traber; MDI, DESY Hamburg

D. Treyer, M. Stadler; PSI

With special thanks to R. Kammering, J. Kruse, D. Liebertz, J. Liebing, J. Thomas, H.-C. Weddig


Sorry for forgetting somebody!

# Goal

Measurement of


- Resonance frequency
- Bandwidth
- Loaded quality factor
- Orthogonal coupling
- Slope Voltage/Offset and Voltage/Charge

Compare with expectation to improve next generation



Reference and Dipole resonator

# Drawing of Cavity BPM




Design frequency of Dipole and Reference resonator = 4.4 GHz

Origin by T. Shintake; SPring-8

Teilernummer: 100-0010 Oberflächennormen nach DIN EN ISO 1302, ISO 4287, ISO 4288 Zeichnungsart: MFT Maßstab: 1:1 (2:1) Datum: 07.06.2008 Zeichner: M. J.		Zeichnungsart: MFT Maßstab: 1:1 (2:1) Datum: 07.06.2008 Zeichner: M. J.		Zeichnungsart: MFT Maßstab: 1:1 (2:1) Datum: 07.06.2008 Zeichner: M. J.	
Eigenschaften von DESY: Alle Rechte vorbehalten. Vor der Nutzung dieser Unterlagen oder der darin enthaltenen Informationen ist die Zustimmung des DESY-Technikreferats erforderlich.					
LGSWorkTing		Material:			
Cavity BPM Schweißgruppe XFEL		Blatt 1 von 1 Datum: 07.06.2008			
Desy-MDI Preis: 130,01 € 36,07		2 07 1621/A_000/2.1		Blatt 1 von 1 Datum: 07.06.2008	
Desy-MDI Preis: 130,01 € 36,07		2 07 1621/A_000/2.1		Blatt 1 von 1 Datum: 07.06.2008	

# Photos



Produced 3 Cavity BPM:

BPM I


BPM II

BPM III

# Measurement setup with Network Analyzer

Port 1 – 4: Dipole resonator

Port 5: Reference resonator




2 channel network analyzer (NWA), measurement of scattering matrix (S-parameter:  $S_{11}$ ,  $S_{22}$  [reflection] and  $S_{12}$ ,  $S_{21}$  [transmission])

Other ports terminated with 50 Ohm

# NWA: Rohde & Schwarz

Up to 8 GHz

N-Cal-Kit from PSI



# Transmission Data: Analysis

Time domain

$$U(t) = U_{out} e^{-\frac{t}{\tau}} \cos(\omega_R t) \Theta(t)$$

$$\omega_R = 2\pi f_R$$

$f_R = \text{resonance frequency}$

$$\tau = \frac{Q_L}{\pi f_s}, \text{ decay time}$$

$Q_L = \text{loaded quality factor}$

$$BW = \frac{f_s}{Q_L}, \text{ bandwidth}$$


$U_{out} \propto \text{beam offset}$

Fourier transformation

Frequency domain

$$F(\omega) = \frac{U_{out}}{\sqrt{2\pi}} \frac{\frac{1}{\tau} + i\omega}{\left(\frac{1}{\tau} + i\omega\right)^2 + \omega_R^2}$$


Adapting  $|F(\omega)|$  to transmission data gives resonance frequency and loaded quality factor



# Dipole resonator: Results

Parameter	Expected	BPM I	BPM II	BPM III
$f_R$ / MHz	4400±17	4408.7 ± 0.6	4419.0 ± 0.5	4414.5 ± 0.6
$BW$ / MHz	74	70.1 ± 2.2	66.7 ± 0.7	72.9 ± 1.5
$Q_L$	60	63.0 ± 2.0	66.3 ± 0.7	60.6 ± 1.3

For resonance frequency the reflection data of dipole resonator used too,  
Systematic shift of frequency to higher values because of roundings








# Orthogonal Coupling

expected: -28 dB

Ports	BPM I / dB	BPM II / dB	BPM III / dB
1-2			
3-4	$-30.9 \pm 0.1$	$-30.7 \pm 0.3$	$-20.0 \pm 0.2$
1-4			
2-3	$-27.0 \pm 0.1$	$-28.8 \pm 0.3$	$-27.5 \pm 0.5$




BPM III is installed in beamline for beam measurement, possible to measure coupling with fast oscilloscope



# Reference Resonator: Analysis

Only Reflection S11 because one port on this resonator



$$S_{11_r} = S_{11} e^{j2\beta L}$$

$$\beta = \frac{2\pi}{v_p}$$

$$v_p = \frac{c}{\sqrt{\epsilon_r}}$$

$c$  – light velocity

$\epsilon_r$  – dielectric

$$Z_r = 50\Omega \frac{1 + S_{11_r}}{1 - S_{11_r}}$$

Measured  $S_{11}$  -> recalculate to  $S_{11_r}$  ->  
recalculate to impedance  $Z$


Adjust  $L$  until  $Re(Z_r)$  constant, point of intersection between  $Re$  and  $|Im|$   
gives bandwidth for  $Q_L$  with  $Z_r + 50$  Ohm

# Reference Resonator: Results

Parameter	Expected	BPM I	BPM II	BPM III
$f_R / \text{MHz}$	$4400 \pm 16$	$4410.6 \pm 0.2$	$4412.0 \pm 0.1$	$4411.5 \pm 0.1$
$BW / \text{MHz}$	70	$67.75 \pm 0.95$	$69.59 \pm 0.92$	$70.63 \pm 0.36$
$Q_L$	62	$65.11 \pm 0.91$	$63.41 \pm 0.85$	$62.46 \pm 0.32$

Systematic shift of frequency to higher values  
because rounding causes this shift

# Transmission Data broad frequency range



Adapting  $|F(\omega)|$  to broad frequency range transmission data gives resonance frequency and loaded quality factor for higher order modes

Global fit does not describe background perfectly, therefore range per mode restricted

# Transmission Data broad frequency range: Results

Mode	Parameter	Expected	BPM I	BPM II
TM <sub>11</sub>	$f_R$ / MHz	4400 ± 17	4409.0 ± 0.7	4419.2 ± 0.4
	$Q_L$	60	62.8 ± 1.9	65.4 ± 0.4
TM <sub>21</sub>	$f_R$ / MHz	5192	5183.1 ± 0.4	5191.5 ± 0.4
	$Q_L$	30	29.2 ± 0.2	29.9 ± 0.2
TM <sub>12</sub>	$f_R$ / MHz	7612	7623.6 ± 3.2	7618.2 ± 1.0
	$Q_L$	54	61.6 ± 0.3	60.3 ± 1.8

Measured values shown

Result: Agreement with short range TM<sub>11</sub>, therefore broad range can be used too

Reflection Data:

Too few data points to get result of quality factor

# Summary Network Analyzer Measurement

- Measured frequency, loaded quality factor of dipole and reference resonator
- Measured orthogonal coupling of dipole resonator
- Frequency shifted to higher values due to rounding
- Orthogonal coupling of BPM III higher because of mechanical tolerances

# BPM III in Beamline

Beam Measurement with Oscilloscope  
(6 GHz, 20GS/s), 123 m cable between  
BPM and Oscilloscope


Available: stepper motor in both  
transverse directions (x, y)

Test of movement range, boundaries  
determined by beam loss monitor:


Horizontal: between -1.57 and 2.05 mm

Vertical: between -2.82 and 0.97 mm

SASE not affected!



# Setup



Reference resonator signal always on channel 4  
Free port terminated with 50 Ohm load



# Attenuation and Phase shift of cables and filters

**Table:** Summary of signal losses and phase differences in [dB] and [°].

Signal (pickup port nr.)	Patch cable tunnel side [dB] ∠ [°]	120 m 7/8" Coaxial cable from [2]	Patch cable "Kryo-Anbau" side	Low pass filter	Total
1 D <sub>Y</sub>	1.50 ∠ 0	10.5 ∠ 0	1.70 ∠ 0	0.49 ∠ 0.0	14.2 ∠ 0.0
2 D <sub>X</sub>	1.35 ∠ 3	10.5 ∠ -2.5	1.45 ∠ -5	0.47 ∠ -0.9	13.8 ∠ -5.4
3 D <sub>Y</sub>	1.60 ∠ -5	10.5 ∠ 17	1.50 ∠ 8	0.45 ∠ 0.8	14.1 ∠ 20.8
4 D <sub>X</sub>	1.55 ∠ 6.5	10.0 ∠ -14	1.50 ∠ 4	0.44 ∠ 3.5	13.5 ∠ 0.0
5 Ref	1.52 ∠ 2.5	9.8 ∠ -7	1.65 ∠ 10	0.54 ∠ -0.9	13.5 ∠ 4.6

In addition 10 dB attenuator for Dipole signals and 20 dB for Reference signal

# Fit function

To increase oscilloscope resolution for amplitude a fit is applied to the time signal, in addition resonance frequency and loaded quality factor is observed:

$$U(t) = U_{out} e^{-\frac{t-t_s}{\tau}} \cos(\omega_R t + \phi) \Theta(t_{trigger} + t_s)$$

$$\omega_R = 2\pi f_R$$

$f_R$  resonance frequency


$$\tau = \frac{Q_L}{\pi f_s}, \text{ decay time}$$

$Q_L$  loaded quality factor

$U_{out} \propto$  beam offset

$\phi$  phase offset

$t_s$  end of transient oscillation





For time between  $t_{trigger}$  and  $t_s$   
(transient oscillation):

$$U(t) = U_{out} e^{-(t-t_s)f_g} \cos(\omega_R t + \phi)$$

$f_g$  gradient frequency


# Fit maximum range




- $t = 14$  ns shows an additional oscillation: reflection between patch cable in tunnel (1.5 m long connected on BPM) and 7/8" coaxial cable
- therefore time of fit limited to  $t_{\text{max}} = 13$  ns

# Fit at small offsets


Channel 1




Channel 2



Channel 3




Channel 4



For small offsets the fit does not describe to the data perfectly, frequency and loaded quality factor at boundary

# Frequency Domain





Because other frequencies contribute to the signal

But amplitudes from fit are useful at small offsets too; resonance frequency and loaded quality factor are taken outside of the beam offset minimum

# Vertical Scan

Charge about 0.65 nC, Voltage corrected to attenuation



Dipole resonator:

$$f_R = 4417.7 \pm 0.8 \text{ MHz}$$

$$Q_L = 56.7 \pm 1.8$$

Left slope: -6.63 V/mm

Right slope: 6.71 V/mm

Reference resonator:

$$f_R = 4407.4 \pm 0.9 \text{ MHz}$$

$$Q_L = 68.8 \pm 1.1$$

$$U_{mean} = 99.1 \pm 1.3 \text{ V}$$

Errors are standard deviation

## Scan Results in horizontal and vertical direction: Slope

	Charge Toroid / nC	Slope  / V/mm	Slope  / V/(mm nC)	$U_{ref}$ / V	$U_{ref}$ / V/nC
X scan	$0.653 \pm 0.010$	$6.62 \pm 0.19$	$10.13 \pm 0.33$	$100.2 \pm 1.2$	$153.4 \pm 3.0$
Y scan	$0.662 \pm 0.009$	$6.67 \pm 0.06$	$10.08 \pm 0.15$	$99.1 \pm 1.3$	$149.8 \pm 2.8$
Average 20 Pulses X scan	$0.656 \pm 0.009$	$6.12 \pm 0.16$	$9.33 \pm 0.28$	$91.2 \pm 1.3$	$138.9 \pm 2.8$
Average 20 Pulses Y scan	$0.649 \pm 0.010$	$5.78 \pm 0.29$	$8.91 \pm 0.47$	$84.7 \pm 1.2$	$130.5 \pm 2.8$

Simulation:

$9.8 \text{ V}/(\text{mm nC})$

$92.6 \text{ V/nC}$

Toroid charge almost constant but reference and dipole data decreasing

Measurement has to be repeated


## Scan Results in horizontal and vertical direction: $f$ , $Q$

Dipole resonator:	NWA Measurement:	Expected:
$f_R = 4416.8 \pm 0.6$ MHz	$4414.5 \pm 0.6$ MHz	$4400 \pm 17$
$Q_L = 57.0 \pm 0.9$	$60.6 \pm 1.3$	60
Reference resonator:		
$f_R = 4407.8 \pm 0.1$ MHz	$4411.5 \pm 0.1$	$4400 \pm 16$
$Q_L = 67.1 \pm 0.4$	$62.46 \pm 0.32$	62

Frequency domain measurement with higher resolution; here only statistical uncertainty



# Crosstalk



Slope of orthogonal Ports shows increase of signal (crosstalk)



Result: -29 dB for all measured orthogonal Ports

Analysis of time data to frequency domain gives slope, results in a crosstalk of -23 dB

NWA Measurement: -20 and -27.5 dB

# Crosstalk in time and frequency domain

Question: crosstalk in time domain smaller compared to frequency domain?



File: Y01

Reason: larger loaded quality factor on orthogonal port gives larger signal in frequency domain

Result: Crosstalk depend on analysis/electronics!

# Summary Beam Measurement and Outlook

- Measured time signals from cavity BPM: dipole and reference resonator
- Slope of Reference Cavity higher as expected
- Measurements has to be repeated with monitoring charge synchronously
- Crosstalk
  
- Next prototypes: 3.3 GHz (cooperation decision)
- Number: 3 for resolution measurement installed at FLASH each with stepper motor in both transverse directions
- Status: Design
- Date of installation: Christmas 2008, measurement until April 2009